

CONSTRUCTION

HAZARD	Satisfactory	Needs Attention	Target Date for Correction	Date Corrected
<i>Carpenters Checklists:</i>				
Portable power saw blade upper half is permanently guarded; and the bottom half has a hinged guard.				
Radial arm and table saws have anti-kickback devices installed.				
Exposed saw teeth are covered by hoods or guards.				
Safety devices are installed on all pneumatic nailers and staplers operating at over 100 psi.				
Employees are trained in proper saw use and safety before working unsupervised.				
Pneumatic tools are disconnected from air supplies when not in use.				
Pneumatic tool is not operated within 10 feet of another employee.				
Safety glasses with side shields are worn at all times.				
Make sure employees do not block off or remove any guard or safety device.				
<i>Excavators Checklists:</i>				
A permit has been issued by Cal/OSHA for excavation deeper than 5 feet.				
Walls of trenches and excavations are shored, benched or sloped to avoid cave-ins.				
Spoils piles are at least 2 feet from the edge of any excavation.				
Excavations are not dug near building foundations, walls and sidewalks.				

Name

Date

CONSTRUCTION

HAZARD	Satisfactory	Needs Attention	Target Date for Correction	Date Corrected
<i>Excavators Checklists (Cont'd.):</i>				
Physical barriers are erected around excavations.				
Before digging, USA must be contacted if underground utilities are possible and property owners contacted to identify hidden utilities.				
Employees do not ride in power shovels, backhoe buckets or other equipment not designated for this purpose.				
<i>Glaziers and Painters Checklist</i>				
Ladders are placed so that the side rails have secure footing.				
Top of the ordinary types of stepladders are not used as steps.				
Ladders are not placed on boxes or other unstable bases to gain height.				
The ladders always extend 3 feet above roof when climbing to the roof of a building.				
Ladders are not placed in front of a door unless the door is guarded, locked or blocked open.				
Ladders are not placed against a window.				
Employees do not climb higher than the third rung from the top on straight ladders, nor the second tread from the top of stepladders.				
Proper ladder is used for the job.				
<div style="display: flex; justify-content: space-between; margin-top: 20px;"> _____ _____ </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> Name Date </div>				