

# FIRE PROTECTION

<b>HAZARD</b>	<b>Satisfactory</b>	<b>Needs Attention</b>	<b>Target Date for Correction</b>	<b>Date Corrected</b>
Is your local fire department well acquainted with your facilities, its location and specific hazards?				
Do you have a fire prevention plan?				
Does your plan describe the type of fire protection equipment and/or systems?				
Have you established practices and procedures to control potential fire hazards and ignition sources?				
Are employees aware of the fire hazards of the materials and processes to which they are exposed?				
If you have a fire alarm system, is it certified as required?				
If you have a fire alarm system, is it tested at least annually?				
If you have interior standpipes and valves, are they inspected regularly?				
If you have outside private fire hydrants, are they flushed at least once a year and on a routine preventive maintenance schedule?				
Are fire doors and shutters in good operating condition?				
Are fire doors and shutters unobstructed and protected against obstructions, including their counterweights?				
Are fire door and shutter fusible links in place?				
Are automatic sprinkler system water control valves, air and water pressures checked weekly/periodically as required?				
Is the maintenance of automatic sprinkler systems assigned to responsible persons or to a sprinkler contractor?				
Are sprinkler heads protected by metal guards, when exposed to physical damage?				
<div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div style="width: 60%; border-top: 1px solid black; text-align: center;">Name</div> <div style="width: 35%; border-top: 1px solid black; text-align: center;">Date</div> </div>				

-over-

# FIRE PROTECTION

HAZARD	Satisfactory	Needs Attention	Target Date for Correction	Date Corrected
Is proper clearance maintained below sprinkler heads?				
Are portable fire extinguishers provided in adequate number and type?				
Are fire extinguisher mounted in readily accessible locations?				
Are employees periodically instructed in the use of extinguishers and fire protection procedures?				
<div style="display: flex; justify-content: space-between; margin-top: 20px;"> <span>_____</span> <span>_____</span> </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <span>Name</span> <span>Date</span> </div>				